

**ADDENDUM NO.   2**



**CITY OF MANDAN  
SOUTH SIDE RESERVOIR COATING**

**MANDAN, ND 58554**

**May 15, 2026**

This Addendum No.   2   forms a part of the Project Manual and modifies the original Bidding Documents as noted within this Addendum. All provisions of the Project Manual not in conflict with this Addendum shall remain in full force. Acknowledge receipt of this Addendum on the outside of the bid envelope and in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This addendum consists of one (1) page(s) and zero (0) attachments.

**SPECIFICATIONS**

Division 09 – Finishes

Section 09 90 01 – Reservoir Painting and Coating

- 1) **Add** Paragraph 2.01 (A.) (3.) with the following text:
  2. Sherwin Williams – Cement-Plex 875 and ConFlex XL
    - a. Adhesion testing per ASTM D4541 will be required at no additional cost to the Owner with use of the Sherwin Williams products over the existing reservoir coating system.
- 2) **Clarification:** Coating system on existing reservoir is Euclid Chemical’s Tammscoat System.

**ATTACHMENT LIST TO THIS ADDENDUM**

- 1) None.

**End of Addendum No.   2**