

JN CONTRACTING



TO: DSGW Architects
3479 Lake Elmo Avenue North
Lake Elmo, MN

RFI #001

ISSUED BY: JN Contracting - Alec Dockter PROJECT: White Shield Housing
DRAWING/SPEC. LOCATION: Multiple JOB#: B24-002
PAGE: Multiple DATE: 7/29/2024

QUESTIONS

1. What size and profile of base and case is desired? Stock sizes for Stained Red Oak are 7/16"x3-1/4" Flat Base and 9/16"x2-1/4" Flat Case.
2. Spec's are calling for stained base and door frames. Please provide a stain color these materials.
3. Are extension jambs at openings 111G, 112G, 121G,122G, 211G, 212G, 221G, 222G, 311G, 312G, 321G, 322G to be Red Oak to match adjacent casing?
4. Is the wood base in the common areas to match the same size and profile as the units?
5. Is the 1x4 Red Oak S4S on the common area entry ceiling to be stained the same color as the unit's base and case?
6. How many rows of closet shelving are to be included at bedrooms, laundry rooms, coat and linen closets?

PROPOSED SOLUTIONS

1. **9/16" X 2 1/4" FOR BASE AND CASING**
2. **DOOR AND BASE STAIN IS TO MATCH CABINET COLOR. STAIN TO BE SELECTED FROM STANDARD COLORS DURING SHOP DRAWING REVIEW**
3. **YES**
4. **NO WOOD BASE IN COMMON AREAS - SEE RFS IN UPCOMING ADDENDUM.**
5. **YES**
6. **ONE ROW PER CLOSET AS SHOWN ON DRAWINGS**

DISTRIBUTION

COST IMPACT: YES x NO UNDETERMINED

If any portions of the RFI is not acceptable or has a cost/schedule impact, please provide written notification of such non-acceptance or impact within seven (7) days of the date of issue hereof. In the absence of such notice of non-acceptance or impact, your unqualified acceptance of this information contained here-in will be deemed conclusive seven (7) days after date of issue.