



TO: DSGW Architect

RFI #003

3479 Lake Elmo Avenue North

Lake Elmo, MN

Issued by: PWS – Justin Sullivan

Project: White Shield Housing

Civil Documents

Date: 7/30/24

Question: Can you ask the engineers what size pipe and what material they want for the storm? They have the runs laid out but nothing on pipe info.

WSB response:

We are unable to provide information on the storm sewer pipe material and sizing until we receive the survey information. The pipe type will depend on the amount of cover which will depend on the inverts of the structures we are tying into.

Cost Impact : YES

Mike Larson

Chief Estimator/Preconstruction Manager

612.760.6957

mlarson@woodstoneinc.com