
TO: ALL CONTRACTORS OF RECORD:

This addendum shall become a part of the original project documents #2602 and Dated August 21, 2026 for the Chippewa Downs Grandstand project, located in Belcourt, North Dakota. Acknowledge receipt of this addendum on the Bid Form, failure to do so may cause disqualification.

BIDDING SPECIFICATION DOCUMENTS:**ITEM #1 SECTION 00100 BID INTENT**

1. As a point of clarification, the Turtle Mountain TERO ordinance and the associated minority preference requirements shall be required for this project.

ITEM #2 SECTION 07421 METAL WALL AND ROOF PANELS

1. Elevate Una-Clad HR Ultra Omega panel shall be an approved equal to the specified MBCI PBR panel.
2. Metal wall panels and associated girts shall be provided and installed by the G.C. on the back and sides of the grandstand structure as shown on the drawings.

ITEM #3 SECTION 09500 ACOUSTIC CEILING TILE

1. USG Eclipse #76775 shall be an approved equal for the ACT specified Armstrong Cirrus
2. USG Kitchen Lay-In #3210 shall be an approved equal for the ACT-2 specified Armstrong Kitchen Zone

ITEM #4 SECTION 11400 KITCHEN EQUIPMENT

1. The equipment list shown in the specifications has incorrect prices shown associated with the equipment. Please disregard these prices.
2. This Section is open to bidders other than Capital City Restaurant Supply as long as the proposed equipment is equal to or greater than the specifications of each piece of equipment.

ITEM #5 SECTION 133416 GRANDSTAND

1. As a point of clarification, the grandstand supplier shall be responsible for supplying and installing the press box and associated siding as well as the roof panels of the grandstand structure. The G.C. shall supply and install the metal wall panels on the back and sides of the grandstand structure including all associated wall girts and fasteners. The G.C. shall also supply and install the metal framing and 1/2" laminated and tempered glass for the glass guardrails attached to the grandstand structure.
2. The grandstand supplier shall include in his bid the cost for design and construction of the grandstand structure concrete foundation.

END OF ADDENDUM #G-1