

JN CONTRACTING



TO: DSGW Architects
3479 Lake Elmo Avenue North
Lake Elmo, MN

RFI #005

ISSUED BY: JN Contracting - Alec Dockter PROJECT: White Shield Housing
DRAWING/SPEC. LOCATION: Holddown Schedule JOB#: B24-002
PAGE: S1.1 DATE: 8/3/2024

QUESTIONS

1. Provide 'ceiling assembly types' for ceilings at corridors, elevator shaft, units, and stair cases. Provide # of layers of drywall on walls and ceilings of the elevator shaft and stair wells.
2. Provide what level of texture is to be sprays on all walls and ceilings?
3. Please Clarify the 1st Floor's Ceiling assembly, since according to page A6.1 Unit's will have suspended ceiling, but on page A3.1 they mention all 1st floor ceiling to be at 9FT height.
4. Confirm what type of 5/8" drywall is to be installed on all walls and ceilings. (Type X or Type C?)
- 5.

PROPOSED SOLUTIONS

1. **CODE, FLOOR PLAN, RCP, AND WALL SECTION SHEETS PROVIDE THESE ANSWERS. SEE UPDATES IN UPCOMING ADDENDUM**
2. **NO TEXTURE.**
3. **ERRANT CEILING SHOWN ON 3/A6.1. SEE UPDATE IN UPCOMING ADDENDUM**
4. **SEE DRAWINGS AND SPEC 09 21 16**
- 5.

DISTRIBUTION

COST IMPACT: YES x NO UNDETERMINED

If any portions of the RFI is not acceptable or has a cost/schedule impact, please provide written notification of such non-acceptance or impact within seven (7) days of the date of issue hereof. In the absence of such notice of non-acceptance or impact, your unqualified acceptance of this information contained here-in will be deemed conclusive seven (7) days after date of issue.