

Addendum Number M3

Museum Center Expansion
Dickinson, North Dakota

GT Architecture
401 West Villard Street Suite 206
Dickinson, ND 58601

March 5, 2026

THE FOLLOWING ADDENDUM ITEMS SHALL BECOME A PART OF THE PLANS AND SPECIFICATIONS FOR THE ABOVE REFERENCED PROJECT AND ITS RECEIPT SHALL BE ACKNOWLEDGED ON THE BID FORM.

THE FOLLOWING ITEMS REFER TO THE SPECIFICATIONS:

Item No. 1: None in this addendum

THE FOLLOWING ITEMS REFER TO THE DRAWINGS:

Item No. 2: Sheet M602
Refer to air drop detail 4/M602.

Remove the 20 micron filter, regulator and lubricator. Provide shut off valve to each air connection and air drop.

Item No. 3: Sheet M402
Refer to keynote 50. Add the following information on the hose reels

Equivalent to COXREELS air hose reel, max operating pressure of 300 psi, 50'-0" hose capacity, retractable with adjustable stop on the hose.

PRIOR APPROVALS

THE FOLLOWING ITEMS ARE APPROVED FOR BIDDING CONTINGENT UPON MEETING THE SPECIFICATIONS:

SECTION

APPROVED

23 34 00

Dust Collector by AQC – dust collector must meet all specifications, 15 hp motor capable of 9" of static pressure. Contractor is responsible for any duct configuration changes that may occur.

23 34 00	Air Scrubber by Camfil – Contractor is responsible for any duct configuration changes that may occur.
23 34 00	Flameless Vent by Boss
Keynote 49	Source Capture Arm by Maxireach

END OF ADDENDUM