

JN CONTRACTING



TO: DSGW Architects
3479 Lake Elmo Avenue North
Lake Elmo, MN

RFI #004

ISSUED BY: JN Contracting - Alec Dockter PROJECT: White Shield Housing
DRAWING/SPEC. LOCATION: Holddown Schedule JOB#: B24-002
PAGE: S1.1 DATE: 7/31/2024

QUESTIONS

1. Holddown Schedule on S1.1 has HD1, HD2, HD3, and HD5 listed. However the plans call for an HD4 holddown in multiple areas. Please provide details on what HD4 is to be or confirm HD5 is a typo on the schedule?
2. _____
3. _____
4. _____
5. _____

PROPOSED SOLUTIONS

1. **SCHEDULE SHOULD BE READ HD4, NOT HD5**
2. _____
3. _____
4. _____
5. _____

DISTRIBUTION

COST IMPACT: YES NO UNDETERMINED

If any portions of the RFI is not acceptable or has a cost/schedule impact, please provide written notification of such non-acceptance or impact within seven (7) days of the date of issue hereof. In the absence of such notice of non-acceptance or impact, your unqualified acceptance of this information contained here-in will be deemed conclusive seven (7) days after date of issue.